

Lynn Richardson

From: Thomas Boyce
Sent: Monday, February 26, 2018 7:45 AM
To: Lynn Richardson
Subject: Morgan Ridge

Lynn,

I have reviewed the revised layout for Morgan Ridge. The septic layout now meets the 100' setback to the neighboring well.

Thomas J. Boyce LSS, REHS
Chatham County Environmental Health