



## Soil Erosion and Sedimentation Control

### LETTER OF APPROVAL

May 21, 2018

Fitch Creations, Inc.  
2000 Fearington Village Center  
Pittsboro, NC 27312

RE:	Project Name:	Fearington Section X Area D Phase 1
	Project Number:	2018-02851
	Acres approved:	26.0
	Submitted by:	Diehl & Phillips, P.A.
	Date Received:	5/21/2018

To The Above Named Person and Entity,

This office has reviewed the subject erosion and sedimentation control plan. We find the plan to be acceptable and hereby issue this Letter of Approval. The enclosed Certificate of Approval must be posted at the job site. This plan approval shall expire two (2) years following the date of approval, if no land-disturbing activity has been undertaken.

Section 10 (l) of the Chatham County Sedimentation and Erosion Control Ordinance requires that a copy of the approved erosion control plan be on file at the job site. Also, this letter gives the notice required by G.S. 113A-61.1(a) of our right of periodic inspection to insure compliance with the approved plan.

North Carolina's Sedimentation Pollution Control Act is performance-oriented, requiring protection of existing natural resources and adjoining properties. If, following the commencement of this project, the erosion and sedimentation control plan is inadequate to meet the requirements of the Chatham County Sedimentation and Erosion Control Ordinance, this office may require revisions to the plan and implementation of the revisions to insure compliance with the Act.

Acceptance and approval of this plan is conditioned upon your compliance with Federal and State water quality laws, regulations, and rules. In addition, local city or county ordinances or rules may also apply to this land-disturbing activity. This approval does not supersede any other permit or approval.



WATERSHED PROTECTION DIVISION  
Environmental Quality Department

P.O. Box 548  
Pittsboro, NC 27312  
PHONE: (919) 545-8343

---

Office: (919) 542-8268 • E-mail: [morgan.dewit@chathamnc.org](mailto:morgan.dewit@chathamnc.org) • Website: [www.chathamnc.org](http://www.chathamnc.org)

Please be aware that your project will be covered by the enclosed NPDES General Stormwater Permit NCGO1000 (Construction Activities). You should first become familiar with all of the requirements for compliance with the enclosed general permit.

Please note that this approval is based in part on the accuracy of the information provided in the Financial Responsibility Form, which you provided. You are requested to file an amended form if there is any change in the information included on the form. Please notify us when you would like to schedule a preconstruction conference. Notification shall be given at least 7 days prior to initiation of activity.

Your cooperation is appreciated.

Sincerely,

A handwritten signature in black ink that reads "Morgan H. DeWit".

Morgan DeWit, PE  
Senior Watershed Specialist  
Watershed Protection Division  
Chatham County

SUBDIVISION: Fearrington Village Section X, Areas D, E, F, G, H, L, M  
 DIRECTIONS: From Pittsboro, take 15/501 toward Chapel Hill for ± 6.8mi. Turn right on Weathersfield. West Camden is ahead on the left.  
 DEVELOPER: Fitch Creations PHONE NUMBER: 919-542-4000

Major Development: X Minor Development: \_\_\_\_\_  
 Development with acreage of 10 acreage of 10 acres or more: \_\_\_\_\_

Proposed road names	OK to submit	DUPLICATED Do not Submit
<u>West Camden (this is being extended)</u>	<u>✓</u>	_____
<u>Guilford</u>	<u>✓</u>	_____
<u>Cleveland</u>	<u>✓</u>	_____
<u>Jackson</u>	<u>✓</u>	_____
<u>Beaufort</u>	<u>✓</u>	_____
<u>Columbus</u>	<u>✓</u>	_____
<u>Onslow</u>	<u>✓</u>	_____

DATE SUBMITTED TO EOC: 5-18-17  
 SUBMITTED BY: Seas Design Group - Cassandra Whitley  
 EOC OFFICER: Denise Suits  
 DATE ROADS APPROVED: 5-19-17  
 DATE FINAL PLAT RECEIVED: \_\_\_\_\_  
 DATE GIVEN TO 911: \_\_\_\_\_  
 DATE CONTACT MADE WITH NUMBERS: \_\_\_\_\_  
 SURROUNDING COUNTY CONTACTED: \_\_\_\_\_  
 PERSON SPOKEN WITH: \_\_\_\_\_  
 COMMENTS: \_\_\_\_\_

revised 4/19/02



SUBDIVISION: Fearrington Village Section X, Areas D, E, F, G, H, L, M

DIRECTIONS: From Pittsboro, take 15/501 toward Chapel Hill for ± 6 mi. Turn right on Weathersfield. West Camden is ahead on left.

DEVELOPER: Fitch Creations PHONE NUMBER: 919-542-4000

Major Development: X Minor Development: \_\_\_\_\_  
Development with acreage of 10 acres or more: \_\_\_\_\_

Proposed road names	OK to submit	DUPLICATED Do not Submit
<u>Currituck</u>	<u>✓</u>	
<u>Davidson</u>	<u>✓</u>	
<u>Alleghany</u>	<u>✓</u>	
<u>Cabarrus</u>	<u>✓</u>	
<u>Orange</u>	<u>✓</u>	
<u>Granville</u>	<u>✓</u>	
<u>Montgomery Place</u>	<u>✓</u>	

DATE SUBMITTED TO EOC: 5-18-17  
SUBMITTED BY: Seas Design Group - Cassandre Whitley  
EOC OFFICER: Denix Suits  
DATE ROADS APPROVED: 5-19-17  
DATE FINAL PLAT RECEIVED: \_\_\_\_\_  
DATE GIVEN TO 911: \_\_\_\_\_  
DATE CONTACT MADE WITH NUMBERS: \_\_\_\_\_  
SURROUNDING COUNTY CONTACTED: \_\_\_\_\_  
PERSON SPOKEN WITH: \_\_\_\_\_  
COMMENTS: \_\_\_\_\_

revised 4/19/02



SUBDIVISION: Ferrington Village Section X, Areas D, E, F, G, H, L, M  
 DIRECTIONS: From Pittsboro, take 15/501 toward Chapel Hill for ±6 mi. Turn right on Weathersfield. West Camden is ahead on the left.  
 DEVELOPER: Fitch Creations PHONE NUMBER: 919-542-4000

Major Development: X Minor Development: \_\_\_\_\_  
 Development with acreage of 10 acres or more: \_\_\_\_\_

Proposed road names	OK to submit	DUPLICATED Do not Submit
<u>Pamlico</u>	<u>✓</u>	
<u>Buncombe</u>	<u>✓</u>	
<u>Halifax</u>	<u>✓</u>	
<u>Millcroft (this is being extended)</u>	<u>✓</u>	
<u>Pasquotank</u>	<u>✓</u>	
<u>Watauga</u>	<u>✓</u>	
<u>Forsyth</u>	<u>✓</u>	

DATE SUBMITTED TO EOC: 5-18-17  
 SUBMITTED BY: Sears Design Group - Cassandra Whitley  
 EOC OFFICER: Darin Suits  
 DATE ROADS APPROVED: 5-19-17  
 DATE FINAL PLAT RECEIVED: \_\_\_\_\_  
 DATE GIVEN TO 911: \_\_\_\_\_  
 DATE CONTACT MADE WITH NUMBERS: \_\_\_\_\_  
 SURROUNDING COUNTY CONTACTED: \_\_\_\_\_  
 PERSON SPOKEN WITH: \_\_\_\_\_  
 COMMENTS: \_\_\_\_\_

 revised 4/19/02





ROY COOPER

Governor

MICHAEL S. REGAN

Secretary

LINDA CULPEPPER

Interim Director

May 30, 2018

COUNTY OF CHATHAM
ATTN: RENEE PASCHAL, COUNTY MANAGER
P O BOX 1809
PITTSBORO, NC 27312

Re: Authorization to Construct (This is not a Final Approval)

Issue Date: May 30, 2018

FEARRINGTON SECTION X AREA D PHASE 1

Serial No.: 18-00399 Water System No.: NC0319126
Chatham County

Dear Applicant:

This letter is to confirm that a complete Engineer's Report and a Water System Management Plan have been received, and that engineering plans and specifications have been approved by the Department for FEARRINGTON SECTION X AREA D PHASE 1, Serial No.: 18-00399.

The "Authorization to Construct" is valid for 24 months from the issue date. Authorization to construct may be extended if the Rules Governing Public Water Supplies and site conditions have not changed (see Rule .0305). The "Authorization to Construct" and the engineering plans and specifications approval letter shall be posted at the primary entrance of the job site before and during construction.

Upon completion of the construction or modification, and prior to placing the new construction or modification into service, the applicant must submit an Engineer's Certification and Applicant's Certification to the Public Water Supply Section.

- Engineer's Certification: in accordance with Rule .0303 (a), the applicant shall submit a certification statement signed and sealed by a registered professional engineer stating that construction was completed in accordance with approved engineering plans and specifications, including any provisions stipulated in the Department's engineering plan and specification approval letter.
Applicant's Certification: in accordance with Rule .0303 (c), the applicant shall submit a signed certification statement indicating that the requirements for an Operation and Maintenance Plan and Emergency Management Plan have been satisfied in accordance with Rule .0307 (d) and (e) and that the system has a certified operator in accordance with Rule .1300. The "Applicant's Certification" form is available at http://www.ncwater.org/ (click on Public Water Supply Section, Plan Review, Plan Review Forms).

Certifications can be sent by mail, fax or attachment to an e-mail message to PWSSection.PlanReview@ncdenr.gov.

If this "Authorization to Construct" is for a new public water system, the owner must submit a completed application for an Operating Permit and the appropriate fee. For a copy of the application for an Operating Permit please call (919) 707-9085.

Once the certifications and permit application and fee (if applicable) are received and determined adequate, the Department will issue a Final Approval letter to the applicant. In accordance with Rule .0309 (a), no portion of this project shall be placed into service until the Department has issued Final Approval.

Please contact us at (919) 707-9100 if you have any questions or need additional information.

Sincerely,

[Handwritten signature of Robert W. Midgette]

Robert W. Midgette, P.E., Operations Branch Head
Public Water Supply Section
Division of Water Resources

cc: ALLEN HARDY, Regional Engineer
DIEHL & PHILLIPS, PA



North Carolina Department of Environmental Quality  
Division of Water Resources

Authorization to Construct

Project Applicant:	COUNTY OF CHATHAM
Public Water System Name and Water System No.:	CHATHAM CO-NORTH NC0319126
Project Name:	FEARRINGTON SECTION X AREA D PHASE 1
Serial No.:	18-00399
Issue Date:	May 30, 2018
Expiration Date:	24 Months after Issue Date

In accordance with NCAC 18C .0305, this Authorization to Construct must be posted  
at the primary entrance to the job site during construction.



ROY COOPER  
*Governor*  
MICHAEL S. REGAN  
*Secretary*  
LINDA CULPEPPER  
*Interim Director*

May 30, 2018

County of Chatham  
Attention: Renee Paschal, County Manager  
PO Box 11809  
Pittsboro, North Carolina 27312

Re: Engineering Plans and Specifications Approval  
Distribution Extension  
Farrington Section X Area D Phase 1  
Chatham Co—North  
Water System No.: NC0319126, Chatham County  
Serial No.: 18-00399

Dear Applicant:

Enclosed please find one copy of the "Application for Approval..." together with one copy of the referenced engineering plans and specifications bearing the Division of Water Resources stamp of approval for the referenced project. These engineering plans and specifications are approved under Division of Water Resources Serial Number 18-00399, dated May 30, 2018.

Engineering plans and specifications prepared by Alan R. Keith, P.E., call for the installation of approximately 3,250 feet of 8-inch water main, 1,565 feet of 6-inch water main, fire hydrants, valves and associated appurtenances along West Camden, Millcroft, Street A, Halifax and Montgomery Place to serve 16 new single-family residences as part of Farrington Section X Area D Phase 1. The proposed 8-inch water main will connect to an existing 8-inch water along Millcroft at a location approximately 200 feet southwest of the intersection with Richmond. The proposed 8-inch water main will connect to an existing 8-inch water main along Weathersfield (NCSR 1812) at the intersection with West Camden.

Please note that in accordance with 15A NCAC 18C .0309(a), no construction, alteration, or expansion of a water system shall be placed into service or made available for human consumption until the Public Water Supply Section has issued Final Approval. Final Approval will be issued and mailed to the applicant upon receipt of both an Engineer's Certification and an Applicant's Certification submitted in accordance 15 A NCAC 18C .0303 (a) and (c).

These plans and specifications in the foregoing application are approved insofar as the protection of public health is concerned as provided in the rules, standards and criteria adopted under the authority of Chapter 130A-317 of the General Statutes. This approval does not constitute a warranty of the design, construction or future operation of the water system.

Nothing Compares

State of North Carolina | Environmental Quality | Water Resources  
Public Water Supply Section  
1634 Mail Service Center | Raleigh, North Carolina 27699-1634  
919 707 9100 | Lab Fax 919 715 6637 | Admin Fax 919 715 4374 | [www.ncwater.org/pws/](http://www.ncwater.org/pws/)



County of Chatham  
Attention: Renee Paschal, County Manager  
Page 2 of 2  
May 30, 2018

One copy of the "Application for Approval..." and a copy of the plans and specifications with a seal of approval from the department are enclosed. One copy of the enclosed documents in a digital format (CD) is being forwarded to our Raleigh Regional Office. The second copy of the CD is being retained in our office.

If the Public Water Supply Section can be of further service, please call (919) 707-9100.

Sincerely,

Handwritten signature of Robert W. Midgette in cursive, followed by the text "/for".

Robert W. Midgette, P.E.  
Operations Branch Head  
Public Water Supply Section

RWM/SB

Enclosures: Approval Documents

cc: Allen Hardy, Raleigh Regional Office  
Chatham County Health Department  
Diehl & Phillips, PA



Water Resources  
Environmental Quality

ROY  
COOPER  
*Governor*  
MICHAEL S. REGAN  
*Secretary*  
LINDA CULPEPPER  
*Interim Director*

June 11, 2018

Roy B. Fitch., Jr. President  
Fitch Creations, Inc., d/b/a Fearington Utilities  
2000 Fearington Village Center  
Pittsboro, NC 27312

**Subject:** Permit No. WQ0040057  
Fitch Creations, Inc., d/b/a Fearington Utilities  
Fearington Section X Area D Phase 1  
Wastewater Collection System Extension Permit  
Chatham County

Dear Mr. Fitch:

In accordance with your application received April 24, 2018 we are forwarding herewith Permit No. WQ0040057 dated June 11, 2018, to Fitch Creations, Inc., d/b/a Fearington Utilities (Permittee) for the construction and operation upon certification of the subject wastewater collection system extension. This permit shall be effective from the date of issuance until rescinded and shall be subject to the conditions and limitations as specified therein. This cover letter shall be considered a part of this permit and is therefore incorporated therein by reference.

Please pay particular attention to the following conditions contained within this permit:

- Condition II.1: This permit shall not be automatically transferable; a permit modification request for a name change must first be approved by this office.
- Condition II.4: Requires that the wastewater collection facilities be properly operated and maintained in accordance with 15A NCAC 2T .0403 or any individual system-wide collection system permit issued to the Permittee.

It shall be the responsibility of the Permittee to ensure that the as-constructed project meets the appropriate design criteria and rules. Failure to comply may result in penalties in accordance with North Carolina General Statute §143-215.6A through §143-215.6C, construction of additional or replacement wastewater collection facilities, and/or referral of the North Carolina-licensed Professional Engineer to the licensing board.

If any parts, requirements, or limitations contained in this permit are unacceptable, you have the right to request an adjudicatory hearing upon written request within 30 days following receipt of this permit. This request must be in the form of a written petition, conforming to Chapter 150B of North Carolina General Statutes, and filed with the Office of Administrative Hearings, 6714 Mail Service Center, Raleigh, NC 27699-6714. Unless such demands are made, this permit shall be final and binding.

Fitch Creations, Inc., d/b/a Fearrington Utilities  
Permit No. WQ0040057

If you need additional information concerning this matter, please contact Jason Robinson at (919) 791-4200 or via e-mail at Jason.T.Robinson@ncdenr.gov.

Sincerely,



---

for Linda Culpepper.  
Interim Director, Division of Water Resources

by S. Daniel Smith, Regional Supervisor  
Water Quality Regional Operations Section  
Raleigh Regional Office  
Division of Water Resources, NCDEQ

cc: Mr. Alan R. Keith PE of Diehl & Phillips, PA: arkeith@bellsouth.net  
Chatham County Health Department  
Raleigh Regional Office Files  
Water Resources Central Files

# North Carolina Department of Environmental Quality

STATE OF NORTH CAROLINA  
ENVIRONMENTAL MANAGEMENT COMMISSION  
DEPARTMENT OF ENVIRONMENTAL QUALITY

WASTEWATER COLLECTION SYSTEM EXTENSION PERMIT


---

In accordance with the provisions of Article 21 of Chapter 143, General Statutes of North Carolina as amended, and other applicable Laws, Rules, and Regulations, permission is hereby granted to the

Fitch Creations, Inc., d/b/a Fearington Utilities  
Chatham County

for the construction and operation of approximately 1,478 linear feet of 8-inch gravity sewer to serve 16 two and three bedroom homes as part of the Fearington Section X area D Phase 1 project, and the discharge of 4,000 gallons per day of collected domestic wastewater into the Fearington Utilities existing sewerage system, pursuant to the application received April 24, 2018, and in conformity with 15A NCAC 2T; the Division's Gravity Sewer Minimum Design Criteria adopted February 12, 1996 and updated in March 2008, as applicable; the Division's Minimum Design Criteria for the Fast-Track Permitting of Pump Stations and Force Mains adopted June 1, 2000 and updated March 2008, as applicable; and other supporting data subsequently filed and approved by the Department of Environmental Quality and considered a part of this permit.

This permit shall be effective from the date of issuance until rescinded and shall be subject to the specified conditions and limitations contained therein.



Linda Culpepper  
Interim Director, Division of Water Resources  
By Authority of The Environmental Management Commission

Permit Number: WQ0040057  
Permit Issued: June 11, 2018

## SUPPLEMENT TO PERMIT COVER SHEET

---

**Fitch Creations, Inc., d/b/a Ferrington Utilities**  
is hereby authorized to:

Construct, and then operate upon certification the aforementioned wastewater collection extension. The sewage and wastewater collected by this system shall be treated in the Ferrington Utilities' Wastewater Treatment Facility in accordance with Permit Number NC0043559.

Permitting of this project does not constitute an acceptance of any part of the project that does not meet 15A NCAC 2T; the Division's Gravity Sewer Minimum Design Criteria adopted February 12, 1996 and updated March 2008, as applicable; and the Division's Minimum Design Criteria for the Fast-Track Permitting of Pump Stations and Force Mains adopted June 1, 2000 and updated March 2008, as applicable, unless specifically mentioned herein. Division approval is based on acceptance of the certification provided by a North Carolina-licensed Professional Engineer in the application. It shall be the Permittee's responsibility to ensure that the as-constructed project meets the appropriate design criteria and rules.

Construction and operation is contingent upon compliance with the Standard Conditions and any Special Conditions identified below.

### I. SPECIAL CONDITIONS

No Special Conditions

### II. STANDARD CONDITIONS

1. This permit shall not be transferable. In the event there is a desire for the wastewater collection facilities to change ownership, or there is a name change of the Permittee, a formal permit request shall be submitted to the Division accompanied by documentation from the parties involved, and other supporting materials as may be appropriate. The approval of this request shall be considered on its merits and may or may not be approved. [15A NCAC 02T.0104; G.S 143-215.1(d3)]
2. This permit shall become voidable unless the wastewater collection facilities are constructed in accordance with the conditions of this permit; 15A NCAC 2T; the Division's Gravity Sewer Minimum Design Criteria adopted February 12, 1996 and updated March 2008, as applicable; the Division's Minimum Design Criteria for the Fast-Track Permitting of Pump Stations and Force Mains adopted June 1, 2000 and updated March 2008, as applicable; and other supporting materials unless specifically mentioned herein. [15A NCAC 02T.0110]



3. This permit shall be effective only with respect to the nature and volume of wastes described in the application and other supporting data. [15A NCAC 02T .0110]
4. The wastewater collection facilities shall be properly maintained and operated at all times. The Permittee shall maintain compliance with an individual system-wide collection system permit for the operation and maintenance of these facilities as required by 15A NCAC 2T .0403. If an individual permit is not required, the following performance criteria shall be met: [15A NCAC 02T .0108(b)]:
  - a. The sewer system shall be effectively maintained and operated at all times to prevent discharge to land or surface waters, and to prevent any contravention of groundwater standards or surface water standards.
  - b. A map of the sewer system shall be developed and shall be actively maintained.
  - c. An operation and maintenance plan including pump station inspection frequency, preventative maintenance schedule, spare parts inventory and overflow response has been developed and implemented.
  - d. Pump stations that are not connected to a telemetry system shall be inspected every day (i.e. 365 days per year). Pump stations that are connected to a telemetry system shall be inspected at least once per week.
  - e. High-priority sewer lines shall be inspected at least once per every six-months and inspections are documented.
  - f. A general observation of the entire sewer system shall be conducted at least once per year.
  - g. Overflows and bypasses shall be reported to the appropriate Division regional office in accordance with 15A NCAC 2B .0506(a), and public notice shall be provided as required by North Carolina General Statute §143-215.1C.
  - h. A Grease Control Program is in place as follows:
    1. For public owned collection systems, the Grease Control Program shall include at least biannual distribution of educational materials for both commercial and residential users and the legal means to require grease interceptors at existing establishments. The plan shall also include legal means for inspections of the grease interceptors, enforcement for violators and the legal means to control grease entering the system from other public and private satellite sewer systems.
    2. For privately owned collection systems, the Grease Control Program shall include at least bi-annual distribution of grease education materials to users of the collection system by the permittee or its representative.
    3. Grease education materials shall be distributed more often than required in Parts (1) and (2) of this Subparagraph if necessary to prevent grease-related sanitary sewer overflows.
  - i. Right-of-ways and easements shall be maintained in the full easement width for personnel and equipment accessibility.

- j. Documentation shall be kept for Subparagraphs (a) through (i) of this Rule for a minimum of three years with exception of the map, which shall be maintained for the life of the system.
5. The Permittee shall report by telephone to a water resources staff member at the Raleigh Regional Office, telephone number (919) 791-4200, as soon as possible, but in no case more than 24 hours, following the occurrence or first knowledge of the occurrence of either of the following:
    - a. Any process unit failure, due to known or unknown reasons, that renders the facility incapable of adequate wastewater transport, such as mechanical or electrical failures of pumps, line blockage or breakage, etc.; or
    - b. Any SSO and/or spill over 1,000 gallons; or
    - c. Any SSO and/or spill, regardless of volume, that reaches surface water

Voice mail messages or faxed information is permissible, but this shall not be considered as the initial verbal report. Overflows and spills occurring outside normal business hours may also be reported to the Division of Emergency Management at telephone number (800) 858-0368 or (919) 733-3300. Persons reporting any of the above occurrences shall file a spill report by completing and submitting Part I of Form CS-SSO (or the most current Division approved form) within five days following first knowledge of the occurrence. This report must outline the actions taken or proposed to be taken to ensure that the problem does not recur. Part II of Form CS-SSO (or the most current Division approved form) can also be completed to show that the SSO was beyond control. [G.S. 143-215.1C(a1)]

6. Construction of the gravity sewers, pump stations, and force mains shall be scheduled so as not to interrupt service by the existing utilities nor result in an overflow or bypass discharge of wastewater to the surface waters of the State. [15A NCAC 02T.0108(b)]
7. Upon completion of construction and prior to operation of these permitted facilities, the completed Engineering Certification form attached to this permit shall be submitted with the required supporting documents to the address provided on the form. A complete certification is one where the form is fully executed and the supporting documents are provided as applicable. Any wastewater flow made tributary to the wastewater collection system extension prior to completion of this Engineer's Certification shall be considered a violation of the permit and shall subject the Permittee to appropriate enforcement actions.

**If the permit is issued to a private entity with an Operational Agreement, then a copy of the Articles of Incorporation, Declarations/Covenants/Restrictions, and Bylaws that have been appropriately filed with the applicable County's Register of Deeds office shall be submitted with the certification.**

A complete certification is one where the form is fully executed and the supporting documents are provided as applicable. Supporting documentation shall include the following:

- a. One copy of the project construction record drawings (plan & profile views of sewer lines & force mains) of the wastewater collection system extension. Final record drawings should be clear on the plans or on digital media (CD or DVD disk) and are defined as the design drawings that are marked up or annotated with after construction information and show required buffers, separation distances, material changes, etc.
- b. One copy of the supporting applicable design calculations including pipe and pump sizing, velocity, pump cycle times, and level control settings, pump station buoyancy, wet well storage, surge protection, detention time in the wet well, and force main, ability to flush low points in force

mains with a pump cycle, and downstream sewer capacity analysis. If a portable power source or pump is dedicated to multiple stations, an evaluation of all the pump stations' storage capacities and the rotation schedule of the portable power source or pump, including travel timeframes, shall be provided.

- c. Changes to the project that do not result in non-compliance with this permit, regulations, or the Minimum Design Criteria should be clearly identified on the record drawings, on the certification in the space provided, or in written summary form.

**Prior to Certification (Final or Partial):** Permit modifications are required for any changes resulting in non-compliance with this permit (including pipe length increases of 10% or greater, increased flow, pump station design capacity design increases of 5% or greater, and increases in the number/type of connections), regulations, or the Minimum Design Criteria. Requested modifications or variances to the Minimum Design Criteria will be reviewed on a case-by-case basis and each on its own merit. Please note that variances to the Minimum Design Criteria should be requested and approved during the permitting process prior to construction. After-construction requests are discouraged by the Division and may not be approved, thus requiring replacement or repair prior to certification & activation. [15A NCAC 02T .0116]

8. Gravity sewers installed greater than ten percent below the minimum required slope per the Division's Gravity Sewer Minimum Design Criteria shall not be acceptable and shall not be certified until corrected. If there is an unforeseen obstacle in the field where all viable solutions have been examined, a slope variance can be requested from the Division with firm supporting documentation. This shall be done through a permit modification with fee. Such variance requests will be evaluated on a case-by-case basis. Resolution of such request shall be evident prior to completing and submitting the construction certification. [ 15A NCAC 02T.0105(n)]
9. A copy of the construction record drawings shall be maintained on file by the Permittee for the life of the wastewater collection facilities. [15A NCAC 02T .0116]
10. Failure to abide by the conditions and limitations contained in this permit; 15A NCAC 2T; the Division's Gravity Sewer Design Criteria adopted February 12, 1996 and updated March 2008, as applicable; the Division's Minimum Design Criteria for the Fast-Track Permitting of Pump Station and Force Mains adopted June 1, 2000 and updated March 2008 as applicable; and other supporting materials may subject the Permittee to an enforcement action by the Division, in accordance with North Carolina General Statutes §143-215.6A through §143-215.6C, construction of additional or replacement wastewater collection facilities, and/or referral of the North Carolina-licensed Professional Engineer to the licensing board. [15A NCAC 02T .0104; 15A NCAC 02T .0108(b-c)]
11. In the event that the wastewater collection facilities fail to perform satisfactorily, including the creation of nuisance conditions, the Permittee shall take immediate corrective action, including those as may be required by this Division, such as the construction of additional or replacement facilities. [15A NCAC 02T .0110; 15A NCAC 02T .0108(b)]
12. The issuance of this permit shall not exempt the Permittee from complying with any and all statutes, rules, regulations, or ordinances that may be imposed by the Division any other Federal, State, or Local government agencies which have jurisdiction or obtaining other permits which may be required by the Division or any other Federal, State, of Local government agencies. [G.S. 143-215.1(b)]

## FAST TRACK SEWER ENGINEERING CERTIFICATION

PERMITTEE: Fitch Creations, Inc., d/b/a Fearington Utilities  
PERMIT #: WQ0040057  
PROJECT: Fearington Section X Area D Phase 1  
ISSUE DATE: June 11, 2018

This project shall not be considered complete nor allowed to operate in accordance with Condition 7 of this permit until the Division has received this Certification and all required supporting documentation. It should be submitted in a manner that documents the Division's receipt. Send the required documentation the Regional Supervisor, Water Quality Regional Operations Section at the address at the bottom.

Any wastewater flow made tributary to the wastewater collection system extension prior to completion of this Certification shall be considered a violation of the permit and shall subject the Permittee to appropriate enforcement actions. The Permittee is responsible for tracking all partial certifications up until a final certification is received. A Final Certification shall be a complete set of record drawings and design calculations regardless of whether partials have been submitted.

### PERMITTEE'S CERTIFICATION

I, the undersigned agent for the Permittee, hereby state that this project has been constructed pursuant to the applicable standards & requirements, the Professional Engineer below has provided applicable design/construction information to the Permittee, and the Permittee is prepared to operate & maintain the wastewater collection system permitted herein or portions thereof.

\_\_\_\_\_  
Printed Name, Title

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date

### ENGINEER'S CERTIFICATION

I, \_\_\_\_\_, as a duly registered Professional Engineer in the State of North Carolina, having been authorized to observe ( periodically,  weekly,  full time) the construction of the project name and location as referenced above for the above Permittee hereby state that, to the best of my abilities, due care and diligence was used in the observation of the construction such that the construction was observed to be built within substantial compliance of this permit; 15A NCAC 02T; the Division of Water Resources' (Division) Gravity Sewer Minimum Design Criteria adopted February 12, 1996 and updated March 2008, as applicable; the Division's Minimum Design Criteria for the Fast-Track Permitting of Pump Stations and Force Mains adopted June 1, 2000 and updated March 2008, as applicable; and other supporting materials.

North Carolina Professional Engineer's Seal w/signature & date:

Final  Partial (include description)



Certification Comments/Qualifiers (attach if necessary):