CHATHAM COUNTY PUBLIC HEALTH DEPARTMENT DIVISION of ENVIRONMENTAL HEALTH

SEWAGE DISPOSAL OPERATIONS PERMIT REVISION

552 Pea Ridge Rd, New Hill, NC 27562	Sanderford, Jackie		
911 ADDRESS	NAME / SUBDIVISION & LOT #		
Date:2/15/19 Residential: Non-Residential: Max. Number of Bedrooms:N/A Other:u	Parcel Number: 5295 p to 9 employees Max.GPD: 240 gpd		
OwnerJackie Sanderford			
Conditions Convert residence to office for logging & grading business This permit authorizes the owner to operate the sewage disposal system in accordance with the state and local rules. The department does recommend that septic tanks be pumped out every 3 to 5 years, and filters be cleaned every 2 to 3 years. In the event of a malfunction contact this office. This certifies that the system has been installed in compliance with applicable NC General Statues and Rules for Sewage Treatment and Disposal and all conditions of the Improvements Permit and Construction Authorization. SYSTEMS CLASSIFIED AS TYPE IV, V OR VI, REQUIRE SYSTEM MANAGEMENT BY A STATE-CERTIFIED OPERATOR. OPERATION PERMIT HOLDERS ARE RESPONSIBLE FOR NOTIFYING SUBSEQUENT OWNERS.			
		Type System: I 🗌 II 🖾 III 🗍 III-B 🗍 IV 🗍	V VI Installer Number Rth5 Environmental Health Specialist
		Conditions/Comments: Two-bedroom mobile home located at 552 Pea Ridge Road to be converted to office space for the owner's logging & grading business. Based on the permit issued in 1985, the system can accommodate up to 9 employees. The drain field has a valve that the owner says is turned regularly. Based on the 1985 permit, it is likely the drain lines are not contained on parcel 5295 and also cross onto parcel 66511 which is also owned by Mr. Sanderford. The current occupant of the mobile home will have to move out in order for this conversion to take place.	