



POOL PERMIT PRE-SEASON AUDIT

No.	Item	Sub-Item (each is required)	Sign/Date	Comments
A. DEPTH MARKINGS				
1)	There are Depth Markings on and around this pool that are at least 4 inches high ; in contrasting color to the background; of a slip resistant finish that contain the word "FEET" or abbreviation "FT" .	a. On the vertical wall of the pool and on the edge of the deck next to the swimming pool		
		b. At points of maximum and minimum depths		
		c. At the transition point		
		d. Separate markings for Diving		
		e. Not greater than 25 feet apart		
B. "NO DIVING" MARKINGS				
2)	There are "NO DIVING" Markings on and around this pool that are at least 4 inches high ; in contrasting color to the background; of a slip resistant finish In areas where water is less than 5 (five) feet deep.	a. On the edge of the deck next to the swimming pool		
		b. Not greater than 25 feet apart		
C. REQUIRED SIGNS				
SWIMMING POOLS				
1)	There are signs around this pool with letters at least 4 inches high that have this exact wording:	a. "WARNING-NO LIFEGUARD ON DUTY"		
2)	There are signs around this pool with letters at least 1 inch high that have this exact wording:	a. "CHILDREN SHOULD NOT USE THE SWIMMING POOL WITHOUT ADULT SUPERVISION"		
		b. "ADULTS SHOULD NOT SWIM ALONE"		
3)	There are signs around this pool that state:	a. The location of the emergency phone if not clearly visible from the pool		
		b. A sign prohibiting pets and glass containers		
		c. "POOL CLOSED" sign (for use whenever the pool is closed)		



POOL PERMIT PRE-SEASON AUDIT

No.	Item		Sub-Item (each is required)	Sign/Date	Comments
4)	There is a sign that is legible and located at the emergency phone that gives:	a.	Dialing instructions, address of the pool location and telephone number		
5)	There is a sign that is visible upon entering the pool that:	a.	Directs pool users to shower before entering pool		
WADING POOLS					
1)	There are signs around this pool with letters at least 4 inches high that have this exact wording:	a.	"WARNING-NO LIFEGUARD ON DUTY"		
2)	There are signs around this pool with letters at least 1/2 inch high(if pool has only one main drain) that have this exact wording:	a.	"WARNING TO PREVENT SERIOUS INJURY DO NOT ALLOW CHILDREN IN WADING POOL IF DRAIN COVER IS BROKEN OR MISSING"		
3)	There are signs around this pool that state:	a.	The location of the emergency phone if not clearly visible from the pool		
		b.	"POOL CLOSED" sign (for use whenever the pool is closed)		
4)	There is a sign that is visible upon entering the pool that:	a.	Directs pool users to shower before entering pool		
5)	Depth Markers and "NO DIVING" markers	a.	Are not required at a wading pool		
SPAS					
1)	There are signs around this pool that state:	a.	The location of the emergency phone if not clearly visible from the pool		
		b.	"POOL CLOSED" sign (for use whenever the pool is closed)		
2)	There is a sign that is visible upon entering the pool that prohibits oils, body lotions, and minerals and:	a.	Directs pool users to shower before entering pool		
3)	Depth Markers and "NO DIVING" markers	a.	Are not required at a wading pool		



POOL PERMIT PRE-SEASON AUDIT

No.	Item	Sub-Item (each is required)	Sign/Date	Comments
4)	There is a "CAUTION" sign at this spa with letters at least 1/2 inch high that has this exact wording:	a. "- PREGNANT WOMEN; ELDERLY PEOPLE AND PERSONS SUFFERING FROM HEART DISEASE, DIABETES, OR HIGH OR LOW BLOOD PRESSURE SHOULD NOT ENTER THE SPA/HOT TUB WITHOUT PRIOR MEDICAL CONSULTATION AND PERMISSION FROM THEIR DOCTOR. -DO NOT USE THE SPA/HOT TUB WHILE UNDER THE INFLUENCE OF ALCOHOL, TRANQUILIZERS, OR OTHER DRUGS THAT CAUSE DROWSINESS OR THAT RAISE OR LOWER BLOOD PRESSURE; - DO NOT USE ALONE - UNSUPERVISED USE BY CHILDREN IS PROHIBITED; - EATER AND EXIT SLOWLY; - OBSERVE REASONABLE TIME LIMITS (THAT IS, 10-15 MINUTES), THEN LEAVE THE WATER AND COOL DOWN BEFORE RETURNING FOR ANOTHER BRIEF STAY; - LONG EXPOSURE MAY RESULT IN NAUSEA, DIZZINESS, OR FAINTING; - KEEP ALL BREAKABLE OBJECTS OUT OF THE AREA."		
D)	WATER QUALITY (.2535)			
1)	Water clear enough to clearly see bottom of pool and pool drain			
2)	Disinfectant residual provided by:	a. free chlorine of at least 1.0 ppm in pools, and 2.0 in wading pools and spas; OR		
		bromine of at least 2.0 ppm; OR		
		biguanide of 30 to 50 ppm		
3)	Pool water pH = (7.2 to 7.8)			
4)	Water temperature of heated pool does not exceed 90°F (swimming pool) or 104°F in Spa			



POOL PERMIT PRE-SEASON

No.	Item	Sub-Item (each is required)	Sign/Date	Comments
5)	Daily written records of water quality and test kit kept on site			
E) POOL MAINTENANCE				
1)	Submerged suction outlets meet ASME/ANSI A112.19.8-2007. Single drains protected (.2537, .2539)			
2)	Pool walls and floor kept clean free of debris and in good repair (.2537)			
3)	Surface skimmers (with weirs, baskets and covers) or gutters clean, in good repair, and functioning properly, no floating debris (.2518, .2537)			
4)	Safety ropes with floats and contrasting color bands provided at shallow area breakpoints (.2515, .2523)			
5)	Diving equipment, ladders, steps and handrails properly placed, in good repair (.2517, .2521)			
6)	Inlets and other fittings in place and in good repair (.2537)			
7)	Contrasting band on steps and benches (.2521, .2516, .2532)			
8)	Spa timer working properly (.2537)			
F) PREMISES				
1)	Body hook and ring buoy with throw rope or lifeguard with rescue tube provided and properly located (.2530, .2537)			
2)	Fence or barrier with self-closing, self-latching gates properly constructed and maintained (.2528, .2537). Gate must self-close and Self-latch from one(1) inch and from wide open.			
3)	Lifeguards present or warning signs posted (.2530)			
4)	Decks unobstructed, properly drained, free of trip hazard (.2522, .2537)			
5)	Pool and deck lighting provided at pools that operate at night (.2524, .2537)			
6)	Pools shall have an emergency telephone. The phone shall be an independent landline phone, with no line extensions or switchboard operator, and permanently mounted on the pool deck area. No direct dial 911 phones will be allowed (phones which have no dial pad). A sign shall be posted at the phone stating, "EMERGENCY DIAL 911" along with the phone number and physical address of the pool. The emergency phone shall be capable of receiving calls with an audible ringer.			



POOL PERMIT PRE-SEASON

No.	Item	Sub-Item (each is required)	Sign/Date	Comments
G) EQUIPMENT ROOM				
1)	Chlorine or bromine automatic feeders that meet NSF Standard 50 (.2535)			
2)	Approved pump, filter, and flow meter operating properly (.2518, .2519)			
3)	Equipment and chemicals kept in a dry, well ventilated enclosure (.2533, .2534, .2537). Ventilation fans should run continuously and not be wired to the light switch			
4)	Valves and pipes identified by color codes or labels (.2518)			
5)	Filter backwash discharged through an air gap (.2513)			
H) DRESSING AND SANITARY FACILITIES				
1)	Bathroom or rest rooms accessible; shower sign posted (.2526)			
2)	Required fixtures provided, clean, and in good repair (.2526)			
3)	Approved water source, no cross connections (.2512)			
4)	Sewage disposed of in a properly operating sewage system (.2513)			
5)	Floors smooth, slip-resistant, kept clean(.2526)			
5)	Hose bibbs and floor drains provided (.2526)			
I)	Once all of the above items have been checked, signed, and dated, please sign and date here. This is a check that you are ready to request an inspection!			Completed