



INSTALLATION & CLEANOUT NOTES:

- 1) INSTALL 50' FROM STORM DRAIN INLETS & SURFACE WATERS UNLESS NO ALTERNATIVE REASONABLY AVAILABLE.
- 2) CLEANOUT WASHOUT WHEN 75% WET CAPACITY.
- 3) ALL DAMAGE TO WASHOUT MUST BE MADE REPAIRED IMMEDIATELY.

NOTES

1. ACTUAL LAYOUT TO BE DETERMINED IN THE FIELD.
2. A CONCRETE WASHOUT SIGN SHALL BE INSTALLED WITHIN 30' OF THE TEMPORARY CONCRETE WASHOUT.
3. MATERIALS USED TO CONSTRUCT TEMPORARY CONCRETE WASHOUT SHALL BE REMOVED FROM THE SITE AND DISPOSED OF OR RECYCLED.
4. HOLES, DEPRESSIONS OR OTHER GROUND DISTURBANCE CAUSED BY THE REMOVAL OF THE TEMPORARY CONCRETE WASHOUT SHALL BE BACKFILLED, REPAIRS AND STABILIZED TO PREVENT EROSION.



STANDARD CONCRETE/PAINT WASHOUT

DETAIL NUMBER

2018-022
SHEET 1 of 1